



KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LABORATORY, MULLASSERY
 PAVARATTY, THRISSUR

Telephone No - 0487-2997763, E-mail - kwa.qcsdl.pvty.@gmail.com

Test Report

Test Report. No : KWA/QCSDL/PVTY-TSR/000377/2024

Report Date :02/02/2024


Customer Name & Address			1. Date of Receipt : 27/01/2024		
GOKULAM PUBLIC SCHOOL BRAHMAKULAM			2. Sampling done by : The Customer		
			3. UID No.of Sample : KWA/QCSDL/PVTY-TSR/S-000377/2024		
			4. Source of Sample :Bore Well		
			5.Sample condition : Good		
			6.Name of sample : Water		
			7. Sample Quantity : 2 Litre		
			8. Test Performing Dates		
			From :27/01/24		
Sl. No.	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500 - 2012	Result
1	Electrical Conductivity	(micro mhos/cm)	IS 3025 (part 14) - 2013 (Reaffirmed 2019) Electrometric method	-	115.50
2	Iron (as Fe)	(mg/litre)	IS 3025 (part 53) - 2003 (Reaffirmed. 2019) 1,10 Phenanthroline method	1.0	0.55
3	Nitrate (as NO ₃)	(mg/litre)	APHA 4500 - NO ₃ B. Ultraviolet screening method	45	BDL

BDL:Below Detection Limit

Remarks:-

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Reviewed by:



* End of Report *

Neethu
 Authorized By: *Neethu Joy*
 Quality Manager,

Quality Control Sub District Laboratory
 Kerala Water Authority

Issue Date: 10/01/2023	Issue No:2	KWA/QCSDL/PVTY-TSR/NO-6- 680 507
Rev.No: 00	Rev Date: 00	

Self attested



KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LABORATORY
MULLASSERY, PAVARATTY-THRISSUR
 Telephone No - 0487-2997763, E-mail - kwa.qcsdl.pvty@gmail.com



TC-10703

Test Report

Test Report. No.:KWA/QCSDL/PVTY-TSR/000377/2024

ULR No.: TC10703230000000207F


Report Date : 02/02/24

Customer Name & Address			1. Date of Receipt : 27/01/2024		
GOKULAM PUBLIC SCHOOL BRAHMAKULAM			2. Sampling done by :The Customer		
			3.UID No.of Sample:KWA/QCSDL/PVTY-TSR/S-000377/24		
			4. Source of Sample :Bore Well		
			5. Sample condition : Good		
			6. Name of sample : Water		
			7. Sample Quantity : 2 litre		
			8. Test Performing Dates		
			From :27/01/24		
SL No.	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500 - 2012	Result
1	Turbidity	(NTU)	IS 3025 (part 10) - 1984 (Reaffirmed 2017) Nephelometric method	1	0.11
2	pH at 25°C		IS 3025 (part 11) - 2022 Electrometric method	6.5 to 8.5	7.67
3	Total Hardness (as Ca CO ₃)	(mg/litre)	IS 3025 (part 21) - 2009 (Reaffirmed, 2019) EDTA Titration method	200	27.72
4	Chloride (as Cl)	(mg/litre)	IS 3025 (part 32) - 1988 (Reaffirmed, 2019) Argentometric titration	250	25.79

Remarks:-

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Reviewed by:



Authorized By Aneetha
 Aneetha Joe
 Quality Manager,
 Quality Control Sub District Laboratory
 Kerala Water Authority
 Mullassery Pavaratty - 680 507

Issue Date 10/01/2023	Issue No:2	KWA/QCSDL/PVTY-TSR/R.No:6
Rev.No: 00	Rev Date:00	

Handwritten signature and notes in blue ink.



Family Health Centre Elavally

Email:- phcelavally@gmail.com , PH: 04872645117

No: 65/2024
22/02/2024

HEALTH AND SANITATION CERTIFICATE

I hereby certify that I have inspected, Sree Gokulam Public School, Brahmakulam and Premises of the educational institution (survey no: 14/1, 14/6 building no: 1/395 (1/425A old), 1/396 (1/425B old), 1/397 (1/425C old) in Elavally Grama Panchayath on 20-02-2024.

I certify that the accommodation for the pupils taught therein is properly ventilated, lighted, neat and clean.

There are adequate number of toilets and latrines with sanitary napkin vending machines and disposal facility, Supply of drinking water is wholesome through a network of taps and pipes connected to overhead tank.

All other necessary aspects of sanitation is satisfactory for 2024-25 academic year.

Place: Elavally

Date : 22/02/2024

Health Inspector

HEALTH INSPECTOR
FHC Elavally